

2024 Report for Board Adult Items of Noncompliance



2024 Adult Noncompliance Status as of 12.31.2024

	County	Facility Name	Item of Noncompliance	Inspection Findings	CAP Due Date - 30 Days
1	Fresno	Main Jail	§ 1058. Use of Restraint Devices.	Unable to determine compliance based on documentation provided.	01/03/25
2	San Diego	Lakeside	§ 1032. Fire Suppression Preplanning.	Staff could not provide monthly fire prevention inspections.	12/19/24
3	Glenn	Glenn County Jail	§ 1027.5 Safety Checks.	The agency is noncompliant with this regulation due to not consistently completing safety checks within the required 60 minutes of this regulation.	11/28/24
4	Glenn	Glenn County Jail	§ 1056. Use of Sobering Cell.	The agency is noncompliant with this regulation due to not consistently completing safety checks within the required 30 minutes of this regulation.	11/28/24
5	Yolo	Monroe Detention Center	§ 1032. Fire Suppression Preplanning.	During the documentation review, BSCC staff determined the Monroe Detention Center is noncompliant with the portion of this regulation where the fire suppression pre-plan is to be developed with the local fire department to be included as part of the policy and procedures manual (Title 15, California Code of Regulations Section 1029). BSCC staff also determined the Monroe Detention Center is noncompliant with the portion of this regulation where fire prevention inspections as required by Health and Safety Code Section 13146.1 (a) and (b) which requires inspections at least once every two years	10/19/24
6					
7					